

3 RESULTS

3.1 RAINWATER PENETRATION

MANUFACTURER Insol Ltd.
MODEL DuoVent version 2

Date 08/05/2015
Contract 58796

Simulated rainfall75mm/hr


Wind speed13.0m/s

louvre height970mm

louvre width950mm

louvre area0.922m²

VENTILATION RATE		WATER FLOW RATES		Effectiveness	Class
Volume m ³ /s	Velocity m/s	Supply l/h	Penetrated l/h		
0.00	0.00	99.0	0.3	99.6%	A
0.46	0.50	99.0	0.4	99.5%	A
0.92	1.00	99.0	0.3	99.5%	A
1.38	1.50	99.0	0.5	99.3%	A
1.84	2.00	99.0	0.8	98.8%	B
2.30	2.50	99.0	1.1	98.4%	B
2.77	3.00	99.0	1.3	98.1%	B
3.23	3.51	99.0	3.0	95.7%	B



3.2 COEFFICIENT OF ENTRY

MANUFACTURER Insol Ltd.
MODEL DuoVent version 2

Date 08/05/2015
Contract 58796

air temperature 19.9 °C

barometer 1004 mbar


air density 1.189 kg/m³

louvre height 970 mm

louvre width 950 mm

louvre area 0.922 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient C _e
	m/s	test m ³ /s	theoretical m ³ /s	
7.7	0.89	0.818	3.317	0.247
10.0	1.02	0.943	3.780	0.249
15.6	1.26	1.164	4.721	0.247
24.2	1.57	1.442	5.880	0.245
38.0	1.97	1.820	7.368	0.247
66.4	2.61	2.407	9.740	0.247
106.4	3.29	3.029	12.330	0.246
143.0	3.85	3.546	14.294	0.248
175.0	4.28	3.940	15.813	0.249
184.4	4.39	4.048	16.232	0.249
mean C _e				0.247
Class				3



3 RESULTS

3.1 COEFFICIENT OF DISCHARGE

MANUFACTURERINSOL Ltd.
MODELZenith Duo

Date 09/08/2016
Contract 59678

air temperature18.7 °C
barometer1017 mbar
air density1.209 kg/m³

louvre height1095 mm
louvre width1069 mm
louvre area1.171 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient C _d
	m/s	test m ³ /s	theoretical m ³ /s	
10.2	1.10	1.293	4.807	0.269
18.7	1.45	1.699	6.509	0.261
24.0	1.63	1.906	7.374	0.258
29.3	1.81	2.124	8.148	0.261
35.2	1.99	2.328	8.931	0.261
50.5	2.34	2.742	10.697	0.256
67.6	2.71	3.171	12.376	0.256
86.4	3.08	3.604	13.992	0.258
105.7	3.40	3.980	15.476	0.257
114.9	3.57	4.177	16.135	0.259
mean C _d				0.260
Class				3

