

3 RESULTS

3.1 RAINWATER PENETRATION


MANUFACTURERINSOL Ltd.
MODELZenith Tri-Vent

Date 15/08/2016
Contract 59678

Simulated rainfall75mm/hr
Wind speed13.0m/s

louvre height1095mm
louvre width1069mm
louvre area1.171m²

VENTILATION RATE		WATER FLOW RATES		Effectiveness	Class
Volume m ³ /s	Velocity m/s	Supply l/h	Penetrated l/h		
0.00	0.00	99.0	0.0	100.0%	A
0.59	0.50	99.0	0.0	100.0%	A
1.17	1.00	99.0	0.0	100.0%	A
1.76	1.50	99.0	0.0	100.0%	A
2.34	2.00	99.0	0.0	100.0%	A
2.93	2.50	99.0	0.4	99.6%	A
3.51	3.00	99.0	1.1	98.8%	B
4.08	3.48	99.0	2.4	97.3%	B




3.2 COEFFICIENT OF ENTRY

MANUFACTURER INSOL Ltd.
MODEL Zenith Tri-Vent

Date 18/08/2016
Contract 59678

air temperature	20.3 °C	louvre height	1095 mm
barometer	998.7 mbar	louvre width	1069 mm
air density	1.181 kg/m ³	louvre area	1.171 m ²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient C _e
	m/s	test m ³ /s	theoretical m ³ /s	
10.0	0.81	0.947	4.817	0.197
13.2	0.93	1.094	5.535	0.198
18.1	1.10	1.293	6.481	0.200
23.2	1.25	1.468	7.338	0.200
36.9	1.59	1.859	9.254	0.201
55.1	1.95	2.278	11.308	0.201
75.5	2.30	2.694	13.237	0.204
101.7	2.68	3.135	15.363	0.204
144.9	3.19	3.731	18.337	0.203
173.8	3.50	4.092	20.083	0.204
mean C _e				0.201
Class				3



3.3 COEFFICIENT OF DISCHARGE

MANUFACTURER INSOL Ltd.
MODEL Zenith Tri-Vent

Date 19/08/2016
Contract 59678

air temperature	20.3 °C	louvre height	1095 mm
barometer	998 mbar	louvre width	1069 mm
air density	1.180 kg/m ³	louvre area	1.171 m ²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient C _e
	m/s	test m ³ /s	theoretical m ³ /s	
10.5	0.65	0.756	4.938	0.153
14.5	0.77	0.899	5.803	0.155
19.9	0.91	1.063	6.798	0.156
27.6	1.07	1.247	8.006	0.156
35.7	1.22	1.423	9.105	0.156
56.7	1.54	1.799	11.475	0.157
100.9	2.06	2.408	15.307	0.157
155.2	2.58	3.017	18.985	0.159
223.5	3.09	3.611	22.782	0.159
266.8	3.38	3.959	24.891	0.159
mean C _e				0.157
Class				4

